

06.06.2019

Kundeninformation

Drehgeber Absolut Multiturn Sendix M3683

Der $MTTF_d$ -Wert für unseren absoluten Multiturn Drehgeber Sendix M3683 wurde von uns berechnet mit:

$MTTF_d$: 51,9 Jahre

T_M : 20 Jahre

Alle weiteren technischen Informationen zu diesem Produkt finden sie auf unserer Homepage unter:
[Link zur Website](#)

Die Berechnung der $MTTF_d$ -Werte wurde in Anlehnung an den Prüfgrundsatz GS-IFA-M21 Kapitel 4.7 *Quantifizierung* des Instituts für Arbeitsschutz der DGUV vorgenommen. Die berechneten Werte berücksichtigen nicht die mechanische Verbindung zur Antriebswelle.

Weitere Informationen zu unseren $MTTF_d$ -Werten finden sie auf unserer Homepage:
[Link zur Website](#)



Arnold Hettich
Produktmanagement

06.06.2019

Customer Information

Rotary Encoder Absolute Multiturn Sendix M3683

The $MTTF_d$ value for our absolute multiturn encoder Sendix M3683 was calculated by:

$MTTF_d$: 51,9 years

T_M : 20 years

For further technical information on this product, please visit:

[Link to our Website](#)

The $MTTF_d$ values were calculated in accordance with chapter 4.7 *Quantification* the principles for the testing and certification of encoders GS-IFA-M21 of the Institute for Occupational Safety and Health of DGUV.

The calculated values do not consider the mechanical connection to the drive shaft.

For further information on our $MTTF_d$ –values, please visit our website:

[Link to our Website](#)



Arnold Hettich
Product Management